

Technical Data

С
200, 150, 100 & 80 NB
17.5 Bar (250 PSI)*
BSPT
Vertical
ANSI 150 or PN16
Galvanised fitting with Brass Valves
35 Kg./ Sq.cm.(500PSI)
200 NB - 7.50 Mtrs. 150 NB - 7 Mtrs. 100 NB - 6.1 Mtrs. 80 NB - 4.7 Mtrs.
200 NB - 65 Kg 150 NB - 42 Kg 100 NB - 27 Kg 80 NB - 18 Kg
Red RAL 3000
UL Listed FM Approved
Specify Size of valve, Trim details
NFPA 13 and NFPA 25

^{*} For 200 NB, FM approval is rated upto 200 PSI (14 Bar)

Description

Rapidrop Alarm Valve model C is a double seated clapper check valve with grooved seat design which ensures positive water flow for alarm operation and is designed for installation in wet pipe sprinkler system. External bypass prevents false alarm under all supply pressure condition. In the event of variable pressure condition, false alarm is prevented with the provision of retard chamber, thus the design allows for installation under both variable and constant supply pressure condition.

Operation of one or more automatic fire sprinklers causes the water to flow into the sprinkler system causing the alarm valve to open, allowing continuous flow of water into the system and transmittal of alarm, both electrical and mechanical.

Alarm Valve Model C



Operation

The fire protection system initially when being pressurized, will allow water to flow into the system until the water supply and system pressure is equalized and the clapper closes the waterway. Once the pressure is stabilized, the fire protection system is ready to be placed in service and then the alarm control valve must be opened. Under normal condition, the water pressure gauge connected to the system side of the alarm valve would show a higher or equal pressure reading than the water pressure gauge connected to the supply side of the valve. This occurs because of the bypass line connecting downstream and upstream side of the alarm valve, which allows water pressure surge to pass without lifting the valve clapper off its seat, thereby causing excessive high pressure surge entrapped in the system side due to presence of a check valve, which generally prevents false alarm.

Sudden high pressure surge, as might be encountered by the start-up of a large fire pump may lead the valve clapper to lift momentarily, allowing water to flow through grooves in the valve seat to the retard chamber. The water in the alarm line is automatically drained out, which helps to prevent false alarm due to successive transient surge in supply pressure. Restriction assembly located beneath the retard chamber consists of inlet and drain restriction orifices, which are established by considering the volume of the retard chamber to meet the listing and approval requirement with regard to time-to-alarm. These requirements represent a balancing of the need to reduce the possible false alarm due to a transient



surge in supply pressure and to achieve desired minimum time- to- alarm following a sprinkler operation.

In constant pressure installation, the retard chamber is not required and the water passing through the groove in the alarm valve seat flows directly through restriction nozzle assembly to activate the mechanical and electrical alarm.

Installation

- 1. Rapidrop Sprinkler alarm valve, Model-C must be installed vertically.
- 2. The alarm valve must be installed in a readily visible and accessible location and provision to be made in such a way that alarm line drain is visible and accessible.
- 3. Where water pressure fluctuates, the variable pressure trim with retard chamber must be used. Under non-fluctuating water pressure condition, the constant pressure trim, which does not include retard chamber, may be used.
- The valve must be installed with trim in accordance with the trim data. Failure to follow the appropriate trim connection guidelines may prevent the device from functioning properly as well as void listing, approval and the manufacturer's warranty.
- 5. Care must be exercised while installing the check valve in the trim to ascertain that they are located with the arrow mark on the check valve body and pointed in proper direction.
- 6. The contraction and expansion associated with an excessive volume of trapped air could cause the waterway clapper to cycle open and shut. This may result in false alarm or an intermittent alarm. To avoid these, it is recommended to have breather valve in the system piping network and a vent valve at the extreme end of the system to bleed-off the air.
- 7. The ball valve provided on the alarm line must be kept open and strapped in set position.
- 8. Pipe connecting the retard chamber and sprinkler alarm bell must be supported properly to avoid loading on the retard chamber.
- All the newly installed system pipes must be flushed properly before alarm valve is put into service.

Inspection and Maintenance

A qualified and trained person must commission the system. After few initial successful tests an authorised person must be trained to perform inspection and testing of the system.

It is recommended to carry out physical inspection

of the system at least twice a week. The inspection should verify that all the control valves are in proper position as per the requirement of the system and no damage has taken place to any component.

It is recommended that the alarm valve and its accessories should be examined and performed for following at least quarterly or as demanded by local authorities to ensure reliable and trouble free operation and service.

- 1. Inspection and testing is to be carried out only by an authorized person. DO NOT TURN OFF the water supply valve to undertake repair work or to test the valve, without placing a roving fire patrol in the area covered by the system. The patrol should continue until the system is back into service. Also do inform the local security personnel and alarm control station, so that a false alarm is not signaled.
- 2. Open the alarm test valve. Verify that the sprinkler alarm bell and/or the pressure alarm switch/electric alarm properly actuate. Close the alarm test valve and verify that water has ceased to flow from the alarm line drain.
- 3. Clean the 20 NB (3/4") strainer provided on the sprinkler alarm bell line.
- Clean the strainer of restriction assembly.
- 5. Inspect the check valve clapper located on the bypass line.


False Alarm

- 1. Inspect the valve rubber clapper face. If worn or damaged, replace it. Be certain that dirt, stone or any other foreign object have not accumulated under the clapper face and lodged in the groove or holes. Clean the clapper face thoroughly. If the seat ring surface is nicked or scoured, it might be possible to repair the same using lapping compound. If not, replace the complete valve or return it to the manufacturer's works for repair.
- 2. If sprinkler alarm bell is not functioning or the impeller is jammed, please follow the maintenance guideline provided in the catalogue for sprinkler alarm bell.
- If pressure alarm switch gives a steady signal, but sprinkler alarm generates an intermittent alarm, check sprinkler alarm bell shaft. If both the sprinkler alarm bell and pressure alarm switch are generating intermittent alarm then check for the possible air which is trapped within the sprinkler system. Trapped air is to be bled off. Also the intermittent alarm may occur due to sudden pressure drop and increase in the system. These problems can be corrected by maintaining a steady supply.


Caution

- The UL Listing,FM Approval and manufacturer's warranty are valid only when the alarm valve is installed with Rapidrop trim set and installed as per installation guidelines.
- Pressure relief valve is required with wet pipe system, when a rise in ambient temperature can cause system pressure to exceed 17.5 Bar (250 PSI). A 17.7 Bar relief valve setting should be used.
- 3) For proper operation of the wet system and to minimize unwanted false alarm, it is important to remove trapped air from the system. The air trapped in the system may also cause intermittent operation of the Water Motor Alarm during sustained flow of water.

Nominal Pressure Loss vs Flow - Alarm Valve (Model C)




ALARM VALVE, MODEL - C SIZE 200 / 150 / 100 / 80 NB



PART LIST

		PART	NO.				Q ⁻	ΓΥ.		
ITEM	200 NB	150 NB	100 NB	80 NB	DESCRIPTION	200 NB	150 NB	100 NB	80 NB	MATERIAL SPECIFICATION
1	2630	2601	2614	2650	HOUSING	1	1	1	1	DUCTILE IRON
2	2632	2607	2616	2652	SEAT	1	1	1	1	BRONZE
3	2600	2600	2600	2600	CLAPPER BUSH	2	2	2	2	BRASS
4	9102	9101	9101	9101	HEX. HEAD BOLT	4	1	1	1	STAINLESS STEEL
5	2636	2628	2619	2656	RUBBER CLAMP	1	1	1	1	STAINLESS STEEL
6	2635	2606	2618	2655	RUBBER SEAT	1	1	1	1	NEOPRENE RUBBER
7	2634	2603	2617	2654	CLAPPER	1	1	1	1	DUCTILE IRON
8	2638	2608	2258	2658	HINGE PIN	1	1	1	1	STAINLESS STEEL
9	2599	2599	2599	2599	BODY BUSH	2	2	2	2	BRASS
10	9004	9004	9004	8373	HEX. HEAD BOLT	6	6	4	4	STEEL
11	9430	9430	9430	9430	SQ. HEAD PLUG	2	2	2	2	FORGED STEEL.
12	2637	2611	2620	2657	COVER GASKET	1	1	1	1	NEOPRENE RUBBER
13	2631	2604	2615	2651	COVER	1	1	1	1	DUCTILE IRON

CONSTANT PRESSURE TRIM FOR ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB



★ TO SUIT AT SITE BY USER

@ REMOVE ITEM (WHEN OPTIONAL TRIM IN USE)

NO - NORMALLY OPEN

NC - NORMALLY CLOSED


NOTE: WHEN PRESSURE SWITCH IS SUPPLIED THEN SL.NO. 22 PLUG NOT REQUIRED.



CONSTANT PRESSURE TRIM FOR ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB

ITEM CODE NO. NO.		DESCRIPTION	SIZE	QUANTITY PER ALARM VALVE SIZE			
		HEX NIPPLE	3/4"	200 NB	150 NB	100 NB	80 NB
2	8625 8620	TEE	3/4"	3	3	3	2
3	8617	ELBOW	3/4"	2	2	2	
3	8616						2
4	8951	PIPE NIPPLE	1/2" 3/4" X 150 mm LONG	1	_	-	
4	9407	PIPE NIPPLE	3/4" x 130 mm LONG		1	_	_
4	9406	PIPE NIPPLE	3/4" x 100 mm LONG	-	1	1	_
4			1/2" x 100 mm LONG				
5	9397 9406	PIPE NIPPLE PIPE NIPPLE	3/4" x 100 mm LONG	1	-	-	1
5 5	9441	PIPE NIPPLE			1	_	_
6	9397	PIPE NIPPLE	3/4" X 80 mm LONG 1/2" x 100 mm LONG	1	1	-	1
6	9397	PIPE NIPPLE	1/2" x 80 mm LONG	'	1		<u>'</u>
	8628	UNION	3/4"	1	1	1	_
7	8627	UNION		'	'	!	
8	9421		1/2"	-	-	-	1
8	9421	SWING CHECK VALVE SWING CHECK VALVE	3/4"	1	1	1	-
9			3/4" x 70 mm LONG	-	-	-	1
	8663 9426	PIPE NIPPLE PIPE NIPPLE	3/4" x 60 mm LONG	1 -	1 -	1	-
9		PIPE NIPPLE				'	-
10	9893 9423	BALL VALVE	½" X 70 mm LONG	-	-	-	1
11				2	2	2	2
12	8633		DUCING HEX NIPPLE 3/4" X 1/2"		-	-	1
13	8632 8631	REDUCING HEX NIPPLE 3/4" X 1/4"		1	1	1	1
	9477	REDUCING HEX NIPPLE BALL VALVE	1/2" X 1/4"				
14 15	8698	HEX NIPPLE		2	2	2	2
16	8357	ELBOW	1/4"	2	2	2	2
17	9526		1/4"	2		2	2
18	2301	PRESSURE GAUGE ALARM TEST LINE ASSEMBLY	1/4"	2	2		1
18	2302	ALARM TEST LINE ASSEMBLY	1/2"		_	1	_
18	2303	ALARM TEST LINE ASSEMBLY	1/2"	-	1	_	_
18	2304	ALARM TEST LINE ASSEMBLY	1/2"	1	_	_	_
19	8355	REDUCING BUSH	3/4" x 1/2"	2	2	2	1
20	1027	RESTRICTION NOZZLE ASSEMBLY	1/2"	1	1	1	1
21	9382	'Y' TYPE STRAINER	3/4"	1	1	1	1
22	8629	PLUG	1/2"	1	1	1	1
23	1416	SPRINKLER ALARM	RAPIDROP MODEL EA (5.9)	1	1	1	1
23	1417	SPRINKLER ALARM	RAPIDROP MODEL EA (5.9)	1	1	1	1
24	8359	HEX NIPPLE	2"	1	1	1	
24	8360	HEX NIPPLE	1-1/4"	-			1
25	9394	ANGLE VALVE	2"	1	1	1	_
25	9392	ANGLE VALVE	1-1/4"	-	-	-	1
26	9592	PIPE NIPPLE	1/2" X 60 mm LONG	2	2	2	2
27	9441	PIPE NIPPLE	3/4" X 80 mm LONG	1	1	1	1
	8624	HEX NIPPLE	1/2"	3	3	3	5
28 29	8619		1/2"			2	3
	0019	TEE	1/4	2	2	4	ა

VARIABLE PRESSURE TRIM FOR ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB



NOTES

- # OPTIONAL TRIM
- (D) DRAIN
- **★** TO SUIT AT SITE BY USER
- @ REMOVE ITEM (WHEN OPTIONAL TRIM IN USE)
- NO NORMALLY OPEN
- NC NORMALLY CLOSED

NOTE: WHEN PRESSURE SWITCH IS SUPPLIED THEN SL.NO. 22 PLUG NOT REQUIRED.

Rapidrop * is a registered trade mark. Rapidrop Global Limited Registered in England No. 5503278



VARIABLE PRESSURE TRIM FOR ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB

ITEM	CODE	DESCRIPTION	SIZE	QUANTITY PER ALARM VALVE SIZE				
NO.	NO.	DESCRIPTION	SIZE		150 NB			
1	8625	HEX NIPPLE	3/4"	4	4	5	2	
2	8620	TEE	3/4"	3	3	3	2	
3	8617	ELBOW	3/4"	2	2	2	-	
3	8616	ELBOW	1/2"	-	-	-	2	
4	8951	PIPE NIPPLE	3/4" X 150 mm LONG	1	-	-	-	
4	9407	PIPE NIPPLE	3/4" x 130 mm LONG	-	1	-	-	
4	9406	PIPE NIPPLE	3/4" x 100 mm LONG	-	-	1	-	
4	9397	PIPE NIPPLE	1/2" x 100 mm LONG	-	-	-	1	
5	9406	PIPE NIPPLE	3/4" x 100 mm LONG	1	-	-	-	
5	9441	PIPE NIPPLE	3/4" X 80 mm LONG	-	1	-	-	
6	9397	PIPE NIPPLE	1/2" x 100 mm LONG	1	-	-	1	
6	9480	PIPE NIPPLE	1/2" x 80 mm LONG	-	1	1	-	
7	8628	UNION	3/4"	1	1	1	-	
7	8627	UNION	1/2"	-	-	-	1	
8	9421	SWING CHECK VALVE	3/4"	1	1	1	-	
8	9455	SWING CHECK VALVE	1/2"	-	-	-	1	
9	8663	PIPE NIPPLE	3/4" x 70 mm LONG	1	1	-	-	
9	9426	PIPE NIPPLE	3/4" x 60 mm LONG	-	-	1	-	
9	9893	PIPE NIPPLE	½" X 70 mm LONG	-	-	-	1	
10	9423	BALL VALVE	1/2"	2	2	2	2	
11	8633	REDUCING HEX NIPPLE	3/4" X 1/2"	-	-	-	1	
12	8632	REDUCING HEX NIPPLE	3/4" X 1/4"	1	1	1	1	
13	8631	REDUCING HEX NIPPLE	1/2" X 1/4"	1	1	1	1	
14	9477	BALL VALVE	1/4"	2	2	2	2	
15	8698	HEX NIPPLE	1/4"	2	2	2	2	
16	8357	ELBOW	1/4"	2	2	2	2	
17	9526	PRESSURE GAUGE	1/4"	2	2	2	2	
18	2301	ALARM TEST LINE ASSEMBLY	1/2"	-	-	-	1	
18	2302	ALARM TEST LINE ASSEMBLY	1/2"	-	-	1	-	
18	2303	ALARM TEST LINE ASSEMBLY	1/2"	-	1	-	-	
18	2304	ALARM TEST LINE ASSEMBLY	1/2"	1	-	-	-	
19	8355	REDUCING BUSH	3/4" x 1/2"	2	2	2	1	
20	1027	RESTRICTION NOZZLE ASSEMBLY	1/2"	1	1	1	1	
21	9382	'Y' TYPE STRAINER	3/4"	1	1	1	1	
22	8629	PLUG	1/2"	1	1	1	1	
23	1416	SPRINKLER ALARM	RAPIDROP MODEL EA (5.9)	1	1	1	1	
23	1417	SPRINKLER ALARM	RAPIDROP MODEL EA (5.9)	1	1	1	1	
24	8359	HEX NIPPLE	2"	1	1	1	-	
24	8360	HEX NIPPLE	1-1/4"	-	-	-	1	




VARIABLE PRESSURE TRIM FOR ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB

	_						
ITEM CODE NO. NO.		I DESCRIPTION	SIZE	QUANTITY PER ALARM VALVE SIZE			
INO.	INO.			200 NB	150 NB	100 NB	80 NB
25	9394	ANGLE VALVE	2"	1	1	1	-
25	9392	ANGLE VALVE	1-1/4"	-	-	-	1
26	9561	PIPE NIPPLE	1/2" X 60 mm LONG	2	2	2	2
27	9441	PIPE NIPPLE	3/4" X 80 mm LONG	1	1	1	1
28	8624	HEX NIPPLE	1/2"	3	3	3	5
29	8619	TEE	1/2"	2	2	2	3
30		PRESSURE SWITCH	1/2" END CONNECTION	1	1	1	1
31	2300	RETARD CHAMBER	RAPIDROP MODEL RA (5.10)	1	1	1	1
32	8625	HEX NIPPLE	3/4".	1	1	1	1


Tel: +44 (0) 1733 847 510 Fax: +44 (0) 1733 553 958 e-mail: rapidrop@rapidrop.com web: www.rapidrop.com



VARIABLE PRESSURE TRIM - SCHEMATIC ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB



CONSTANT PRESSURE TRIM - SCHEMATIC ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB



NON RETURN VALVE

⋈ VALVE

△ ANGLE VALVE

₩ STRAINER

NC - NORMALLY CLOSED

RESTRICTION NOZZLE

ASSEMBLY.

STOP VALVE

OPTIONAL

NO - NORMALLY OPEN

AV - ALARM VALVE

G - SPRINKLER ALARM

PG - PRESSURE GAUGE

PS - PRESSURE SWITCH

RC - RETARD CHAMBER

AC - SPRINKLER ALARM CONTROL VALVE

AT - SPRINKLER ALARM TEST VALVE

--- BY USER (NOT IN 'HD' SCOPE OF SUPPLY)

NOTE:-


1) SPRINKLER ALARM CONTROL VALVE MUST BE KEPT NORMALLY OPEN IF THIS VALVE IS KEPT CLOSED THE SPRINKLER ALARM BELL/ELECTRIC ALARM WILL NOT SIGNAL.


2) SPRINKLER ALARM TEST VALVE MUST BE KEPT NORMALLY CLOSED CONDITION. VALVE IS OPENED TO TEST THE SPRINKLER ALARM BELL/ELECTRIC ALARM.



OVERALL DIMENSION WITH TRIM ALARM VALVE MODEL - C 200 / 150 / 100 / 80 NB

A) CONSTANT PRESSURE TRIM






INSTALLATION MEASUREMENT IN MM. (Approximate)

WITH CONSTANT PRESSURE TRIM							
SIZE	80 NB	100 NB	150 NB	200 NB			
Α	270	320	325	350			
В	380	400	425	450			
С	440	440	440	460			
D	115	130	170	185			
E	185	205	215	250			

B) VARIABLE PRESSURE TRIM



INSTALLATION MEASUREMENT IN MM. (Approximate)

WITH VARIABLE PRESSURE TRIM							
SIZE 80 NB		·		200 NB			
Α	270	320	325	350			
В	450	495	495	500			
С	440	440	440	460			
D	115	130	170	185			
Е	185	205	215	250			

DRAIN



NOTICE: The equipment presented in this bulletin is to be installed in accordance with the lasted publication standards of NFPA or other similar organisations also with the provision of government codes or ordinances where applicable. The information provided by us are to the best of our knowledge and belief, and are general guidelines only. Site handling and installation control is beyond our reach. Hence we give no guarantee for result and take no liability for damages, loss or penalties whatsoever, resulting from our suggestion, information, recommendation or damages due to our product. Product development is a continuous programme of Rapidrop and hence the right to modify any specification without prior notice is reserved with the company.